

Table 1

One and Two Connection Water Supplies

Type of Water Supply One to two connections (Not a single-family residence or "Same Farm Exemption")	Drilled Well Inspection	Volume Test	Coliform Bacteria Test	Initial Complete Inorganic Chemical (IOC) Testing	Sanitary Control Area Covenant	Water User Agreement
A facility, utilizing a drilled well serving two or less connections that include a dwelling and/or business with employees that are family members and no public access.	No	No If no well log then must conduct one hour pump test and meet 4 gpm flows or adequate storage.	Yes Prior to occupancy and within a year. Point of use treatment allowed for Primary MCL exceedence with Notice to Property Title.	No Nitrate test within the year. Arsenic in identified areas. Additional testing as identified. Point of use treatment allowed for primary MCL exceedence with Notice to Property Title.	No	No
A facility with employees and/or public access with two or less connections and less than 25 people per day.	Yes	No If well log indicates flows of >20 gpm otherwise 4-hour pump test is required with minimum flow of 4 gpm or adequate storage.	Yes Prior to occupancy and within a year. If positive for bacteria must meet Group B requirements.	Yes If primary MCL exceedence must meet Group B requirements.	Yes	No
Two-Party Well A water supply that serves two dwelling units on separate properties.	Yes	No If well log shows flows of greater than 20 gpm otherwise 4-hour pump test is required with minimum flow of 4 gpm or adequate storage.	Yes Prior to occupancy and within a year. If positive for bacteria must meet Group B requirements.	Yes If primary MCL exceedence must meet Group B requirements. Secondary MCLs are not required to be treated.	Yes	Yes Primary and secondary MCL exceedences or treatment must be included.
Shared Well A water supply that serves two dwelling units on the same property, not ADU.	Yes	No If well log shows flows of greater than 20 gpm otherwise 4-hour pump test is required with minimum flow of 4 gpm or adequate storage.	Yes Prior to occupancy and within a year. If primary MCL exceedence must meet Group B requirements, point of use treatment is allowed.	No Nitrate within the year. Arsenic in identified areas. Additional testing as identified. If primary MCL exceedence must meet Group B requirements, point of use treatment is allowed.	No Unless SCA is not contained within lot.	No Unless primary MCLs exceedence treatment and notice on Property Title required.
Two Connection Supply A drilled well that serves two dwelling units one of which is an ADU or Temporary ADU.	Yes	No If well log shows flows of greater than 20 gpm otherwise 4-hour pump test is required with minimum flow of 4 gpm or adequate storage.	Yes Prior to occupancy and within a year. Point of use treatment allowed for primary MCL exceedence with Notice to Property Title.	No Nitrate test within the year. Arsenic in identified areas. Additional testing as identified. Point of use treatment allowed for primary MCL exceedence with Notice to Property Title.	No Unless SCA is not contained within lot.	No